

SOUTHWEST FLORIDA WATER MANAGEMENT DISTRICT
ENVIRONMENTAL RESOURCE
INDIVIDUAL CONSTRUCTION
PERMIT NO. 43008227.005

Expiration Date: August 28, 2012

PERMIT ISSUE DATE: August 28, 2007

This permit is issued under the provisions of Chapter 373, Florida Statutes, (F.S.), and the Rules contained in Chapters 40D-4 and 40, Florida Administrative Code, (F.A.C.). The permit authorizes the Permittee to proceed with the construction of a surface water management system in accordance with the information outlined herein and shown by the application, approved drawings, plans, specifications, and other documents, attached hereto and kept on file at the Southwest Florida Water Management District (District). Unless otherwise stated by permit specific condition, permit issuance constitutes certification of compliance with state water quality standards under Section 401 of the Clean Water Act, 33 U.S.C. 1341. All construction, operation and maintenance of the surface water management system authorized by this permit shall occur in compliance with Florida Statutes and Administrative Code and the conditions of this permit.

PROJECT NAME: The Madison

GRANTED TO: Post Publishing, Inc.
9741 International Court North
St. Petersburg, FL 33716-4807

ABSTRACT: This Individual permit authorization is for the construction of a mixed-use community consisting of multi-story condominiums and retail space. The project site is located on approximately 12.70 acres in Section 12, Township 30 South, and Range 16 East in Pinellas County. The project is bordered by Dr. Martin Luther King, Jr. Street on the east, 118th Avenue on the south, 10th Way North on the west and the Bay Isle Key development on the north. The site consists of two lots, Lot 1 and Lot 2, that are separated by a 100-foot drainage easement over a tidal canal. The proposed work for each lot will include multi-story complexes with courtyards and associated parking. Each lot will have a pond that will provide water quality treatment. The water quality treatment method will be effluent filtration. Attenuation is not required since the project discharges to tidal waters. It was demonstrated that the design high water elevations for the 25-year/24-hour storm event will be contained within the pond banks. Operation and maintenance of the surface water management system will be the responsibility of The Madison Condominium Association.

There are 3.80 acres of wetlands and upland cut surface waters within the project area. There will be 2.07 acres of wetlands and 0.09-acre of upland cut surface waters permanently impacted for the development. The wetland impacts will be offset by the wetland mitigation of 1.18 acres of wetlands creation and 0.17-acre of wetland enhancement. The wetland impacts and the mitigation were reviewed using Unified Mitigation Assessment Method (UMAM).

OP. & MAINT. ENTITY: The Madison Condominium Association

COUNTY: Pinellas

SEC/TWP/RGE: 12/30S/16E

**TOTAL ACRES OWNED
OR UNDER CONTROL:** 12.70

Permit No.: 43008227.005
Project Name: The Madison

Mitigation Information	Count of Mitigation: 2							
Mitigation Name	Creation/Restoration		Enhancement		Preservation		Other	
	Acres	Functional Gain	Acres	Functional Gain	Acres	Functional Gain	Acres	Functional Gain
M1-A, M1-B, M2-A & M2-B	1.18	0.55	0.00	0.00	0.00	0.00	0.00	0.00
Enhancement M2-A	0.00	0.00	0.17	0.05	0.00	0.00	0.00	0.00
TOTAL	1.18	0.55	0.17	0.05	0.00	0.00	0.00	0.00

Mitigation Comments: The 2.07 acres of permanent wetland impacts will be offset by the creation of 1.18-acre of saltwater marsh in four mitigation areas and the enhancement of 0.17-acre of a Brazilian pepper dominated wetland. The wetland mitigation was reviewed utilizing the UMAM and the wetland creation areas and the wetland enhancement area will provide 0.60 functional gain units to offset the 0.57 functional loss units for the wetland impacts. The 0.03-unit of excess functional gain will offset any secondary impact of the project and there will be no functional gain units available from this project for future use.

Wetland impacts and related mitigation:

Wetland: Wetland 1

Impact Area(s): 1-1

Mitigation: M1-A, M1B, M2A, & M2B

Wetland: Wetland 2

Impact Area(s): 2-1

Mitigation: M1-A, M1B, M2A, & M2B

Wetland: Wetland 3

Impact Area(s): 3-1

Mitigation: M1-A, M1B, M2A, & M2B

Wetland: Wetland 4

Impact Area(s): 4-1

Mitigation: M1-A, M1B, M2A, & M2B

Wetland: Wetland 5

Impact Area(s): 5-1

Mitigation: M1-A, M1B, M2A, & M2B, Enhancement M2A

A regulatory conservation easement is not required.

A proprietary conservation easement is not required.

SPECIFIC CONDITIONS

1. If the ownership of the project area covered by the subject permit is divided, with someone other than the Permittee becoming the owner of part of the project area, this permit shall terminate, pursuant to Section 40D-1.6105, F.A.C. In such situations, each land owner shall obtain a permit (which may be a modification of this permit) for the land owned by that person. This condition shall not apply to the division and sale of lots or units in residential subdivisions or condominiums.
2. Unless specified otherwise herein, two copies of all information and reports required by this permit shall be submitted to:

- D. Species composition of recruiting wetland vegetation is indicative of the wetland type specified in criterion "A".
- E. Coverage by nuisance or exotic species does not exceed five percent at any location in the mitigation site and five percent for the entire mitigation site.
- F. The wetland mitigation area can be determined to be a wetland or other surface water according the Chapter 62-340, F.A.C.

This criterion must be achieved within three years of mitigation area construction. The Permittee shall complete any activities necessary to ensure the successful achievement of the mitigation requirements by the deadline specified. Any request for an extension of the deadline specified shall be accompanied with an explanation and submitted as a permit letter modification to the District for evaluation.

The mitigation area may be released from monitoring and reporting requirements and be deemed successful at any time during the monitoring period if the Permittee demonstrates that the conditions in the mitigation area have adequately replaced the wetland and surface water functions affected by the regulated activity and that the site conditions are sustainable.

- 7. The Permittee shall monitor and maintain the wetland mitigation areas until the criteria set forth in the Wetland Mitigation Success Criteria Conditions above are met. The Permittee shall perform corrective actions identified by the District if the District identifies a wetland mitigation deficiency.
- 8. The Permittee shall undertake required maintenance activities within the wetland mitigation areas as needed at any time between mitigation area construction and termination of monitoring, with the exception of the final year. Maintenance shall include the manual removal of all nuisance and exotic species, with sufficient frequency that their combined coverage at no time exceeds the Wetland Mitigation Success Criteria Conditions above. Herbicides shall not be used without the prior written approval of the District.
- 9. A Wetland Mitigation Completion Report shall be submitted to the District within 30 days of completing construction and planting of the wetland mitigation areas. Upon District inspection and approval of the mitigation areas, the monitoring program shall be initiated with the date of the District field inspection being the construction completion date of the mitigation areas. Monitoring events shall occur between March 1 and November 30 of each year. An Annual Wetland Monitoring Report shall be submitted upon the anniversary date of District approval to initiate monitoring.

Annual reports shall provide documentation that a sufficient number of maintenance inspection/activities were conducted to maintain the mitigation areas in compliance with the Wetland Mitigation Success Criteria Conditions above. Note that the performance of maintenance inspections and maintenance activities will normally need to be conducted more frequently than the collection of other monitoring data to maintain the mitigation areas in compliance with the Wetland Mitigation Success Criteria Conditions above.

Monitoring Data shall be collected semi-annually.

- 10. Termination of monitoring for the wetland mitigation areas shall be coordinated with the District by:
 - A. notifying the District in writing when the criteria set forth in the Wetland Mitigation Success Criteria Conditions have been achieved;

18. Rights-of-way and easement locations necessary to construct, operate and maintain all facilities, which constitute the permitted surface water management system, shall be shown on the final plat recorded in the County Public Records. Documentation of this plat recording shall be submitted to the District with the Statement of Completion and Request for Transfer to Operation Entity Form, and prior to beneficial occupancy or use of the site. The plat shall include the locations and limits of the following:
 - A. all wetlands, and
 - B. wetland buffers.
19. Copies of the following documents in final form, as appropriate for the project, shall be submitted to the Tampa Regulation Department:
 - A. homeowners, property owners, master association or condominium association articles of incorporation, and
 - B. declaration of protective covenants, deed restrictions or declaration of condominium.

The Permittee shall submit these documents either: (1) within 180 days after beginning construction or with the Statement of Completion and as-built construction plans if construction is completed prior to 180 days, or (2) prior to any lot or unit sales within the project served by the surface water management system, whichever occurs first.
20. The operation and maintenance entity shall submit inspection reports in the form required by the District, in accordance with the following schedule.

For systems utilizing effluent filtration or exfiltration **or** systems utilizing effluent filtration or exfiltration **and** retention or wet detention, the inspections shall be performed 18 months after operation is authorized and every 18 months thereafter.
21. Prior to installation of the filter media, the Permittee's contractor shall submit a certified test of the media to the Permittee's Professional Engineer and the District. The test shall address the following parameters: uniformity coefficient, effective grain size, sieve analysis, percent silts, clays and organic matter, and permeability testing (constant head). If testing indicates the actual permeability rate is less than the value specified in the permitted design, a permit modification will be required to lengthen the effluent filtration system. The Permittee shall also notify the Surface Water Regulation Manager, Tampa Regulation Department, at least 48 hours prior to commencement of construction of the effluent filtration system, so that District staff may observe this construction activity.
22. The District, upon prior notice to the Permittee, may conduct on-site inspections to assess the effectiveness of the erosion control barriers and other measures employed to prevent violations of state water quality standards and avoid downstream impacts. Such barriers or other measures should control discharges, erosion, and sediment transport during construction and thereafter. The District will also determine any potential environmental problems that may develop as a result of leaving or removing the barriers and other measures during construction or after construction of the project has been completed. The Permittee must provide any remedial measures that are needed.
23. This permit is issued based upon the design prepared by the Permittee's consultant. If at any time it is determined by the District that the Conditions for Issuance of Permits in Rules 40D-4.301 and 40D-4.302, F.A.C., have not been met, upon written notice by the District, the Permittee shall obtain a permit modification and perform any construction necessary thereunder to correct any

EXHIBIT "A"

1. All activities shall be implemented as set forth in the plans, specifications and performance criteria as approved by this permit. Any deviation from the permitted activity and the conditions for undertaking that activity shall constitute a violation of this permit.
2. This permit or a copy thereof, complete with all conditions, attachments, exhibits, and modifications, shall be kept at the work site of the permitted activity. The complete permit shall be available for review at the work site upon request by District staff. The permittee shall require the contractor to review the complete permit prior to commencement of the activity authorized by this permit.
3. For general permits authorizing incidental site activities, the following limiting general conditions shall also apply:
 - a. If the decision to issue the associated individual permit is not final within 90 days of issuance of the incidental site activities permit, the site must be restored by the permittee within 90 days after notification by the District. Restoration must be completed by re-contouring the disturbed site to previous grades and slopes re-establishing and maintaining suitable vegetation and erosion control to provide stabilized hydraulic conditions. The period for completing restoration may be extended if requested by the permittee and determined by the District to be warranted due to adverse weather conditions or other good cause. In addition, the permittee shall institute stabilization measures for erosion and sediment control as soon as practicable, but in no case more than 7 days after notification by the District.
 - b. The incidental site activities are commenced at the permittee's own risk. The Governing Board will not consider the monetary costs associated with the incidental site activities or any potential restoration costs in making its decision to approve or deny the individual environmental resource permit application. Issuance of this permit shall not in any way be construed as commitment to issue the associated individual environmental resource permit.
4. Activities approved by this permit shall be conducted in a manner which does not cause violations of state water quality standards. The permittee shall implement best management practices for erosion and a pollution control to prevent violation of state water quality standards. Temporary erosion control shall be implemented prior to and during construction, and permanent control measures shall be completed within 7 days of any construction activity. Turbidity barriers shall be installed and maintained at all locations where the possibility of transferring suspended solids into the receiving waterbody exists due to the permitted work. Turbidity barriers shall remain in place at all locations until construction is completed and soils are stabilized and vegetation has been established. Thereafter the permittee shall be responsible for the removal of the barriers. The permittee shall correct any erosion or shoaling that causes adverse impacts to the water resources.
5. Water quality data for the water discharged from the permittee's property or into the surface waters of the state shall be submitted to the District as required by the permit. Analyses shall be performed according to procedures outlined in the current edition of Standard Methods for the Examination of Water and Wastewater by the American Public Health Association or Methods for Chemical Analyses of Water and Wastes by the U.S. Environmental Protection Agency. If water quality data are required, the permittee shall provide data as required on volumes of water discharged, including total volume discharged during the days of sampling and total monthly volume discharged from the property or into surface waters of the state.

15. This permit is valid only for the specific processes, operations and designs indicated on the approved drawings or exhibits submitted in support of the permit application. Any substantial deviation from the approved drawings, exhibits, specifications or permit conditions, including construction within the total land area but outside the approved project area(s), may constitute grounds for revocation or enforcement action by the District, unless a modification has been applied for and approved. Examples of substantial deviations include excavation of ponds, ditches or sump areas deeper than shown on the approved plans.
16. The operation phase of this permit shall not become effective until the permittee has complied with the requirements of the conditions herein, the District determines the system to be in compliance with the permitted plans, and the entity approved by the District accepts responsibility for operation and maintenance of the system. The permit may not be transferred to the operation and maintenance entity approved by the District until the operation phase of the permit becomes effective. Following inspection and approval of the permitted system by the District, the permittee shall request transfer of the permit to the responsible operation and maintenance entity approved by the District, if different from the permittee. Until a transfer is approved by the District, the permittee shall be liable for compliance with the terms of the permit.
17. Should any other regulatory agency require changes to the permitted system, the District shall be notified of the changes prior to implementation so that a determination can be made whether a permit modification is required.
18. This permit does not eliminate the necessity to obtain any required federal, state, local and special District authorizations including a determination of the proposed activities' compliance with the applicable comprehensive plan prior to the start of any activity approved by this permit.
19. This permit does not convey to the permittee or create in the permittee any property right, or any interest in real property, nor does it authorize any entrance upon or activities on property which is not owned or controlled by the permittee, or convey any rights or privileges other than those specified in the permit and Chapter 40D-4 or Chapter 40D-40, F.A.C.
20. The permittee shall hold and save the District harmless from any and all damages, claims, or liabilities which may arise by reason of the activities authorized by the permit or any use of the permitted system.
21. Any delineation of the extent of a wetland or other surface water submitted as part of the permit application, including plans or other supporting documentation, shall not be considered binding unless a specific condition of this permit or a formal determination under section 373.421(2), F.S., provides otherwise.
22. The permittee shall notify the District in writing within 30 days of any sale, conveyance, or other transfer of ownership or control of the permitted system or the real property at which the permitted system is located. All transfers of ownership or transfers of a permit are subject to the requirements of Rule 40D-4.351, F.A.C. The permittee transferring the permit shall remain liable for any corrective actions that may be required as a result of any permit violations prior to such sale, conveyance or other transfer.
23. Upon reasonable notice to the permittee, District authorized staff with proper identification shall have permission to enter, inspect, sample and test the system to insure conformity with District rules, regulations and conditions of the permits.
24. If historical or archaeological artifacts are discovered at any time on the project site, the permittee shall immediately notify the District and the Florida Department of State, Division of Historical Resources.
25. The permittee shall immediately notify the District in writing of any previously submitted information that is later discovered to be inaccurate.